



ADD TWO WALL MOUNTED STAIR LIGHTS SAME CIRCUIT ALL LIGHTS MOUNTED/CENTRED 100mm ABOVE RESPECTIVE STEP/LANDING

UNDER TILE HEATING TO ENSUITE SPACE

OMIT DOUBLE GPO

HEIGHT IS CORRECT

OMIT PENDANT AND 2-WAY CIRCUIT & SWITCHES

RELOCATE SWITCH HERE

ADD TWO DOUBLE GPO JUST BELOW DESK

CHANGE STRIP CIRCUIT AND SWITCH LOCATION

MOUNT BRACKET HORIZONTALLY WITH LIGHT ARM CLOSER TO SPLIT SYSTEM LOCATION

- NOTES:
- MAXIMUM 5W/M2 FOR ARTIFICIAL
 - MAXIMUM 4W/M2 FOR VERANDA BY A DAYLIGHT SENSOR OR HAVE THAN 40 LUMENS/W
 - ALL BUILDING FABRIC PENETRATION SEALING
 - ALL BUILDING SERVICES TO COMPLY
 - EXHAUST FANS TO DISCHARGE 25L/S FOR BATHROOMS AND ENSUITE
 - ALL MECHANICAL VENTILATION
 - WALL MOUNTED AND BULKHEAD
 - PROPOSED INSTALLATION OF A ENERGY REPORT AS REQUIRED

ED CEILING PLAN